

Preliminary Assessment Report

Project 3023582, 3406 15TH AVE W

Assessment Completed: 2/23/2016

Project Description: EDG - Construct 26,892 sq ft, residential buildings (townhomes) with 22 units and 16 parking spaces. REVISED FROM: 22 Town House Project with 16 parking stalls from alley access

Primary Applicant: [Jonathan Lemons](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Seattle Department of Construction and Inspections (SDCI) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with SDCI. **Please bring a copy of this report to your intake appointment.**

Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

SDCI Drainage Requirements

Eric Dripps, (206) 727-3676, Eric.Dripps@seattle.gov

SDCI Land Use Requirements

Nikole Coleman, (206) 684-5043, Nikole.Coleman@seattle.gov

SDCI Preapplication Site Visit Requirements

Roxanne Kennedy, (206) 615-1283, Roxanne.Kennedy@seattle.gov

Seattle City Light Requirements

Ray Ramos, (206) 615-1193, ray.ramos@seattle.gov

Seattle Department of Transportation Requirements

Emily Ehlers, (206) 684-8264, Emily.Ehlers@seattle.gov

Seattle Public Utilities Requirements

Jim Mahady, (206) 684-5950, Jim.Mahady@seattle.gov

Water Availability

SPU Staff, (206) 684-3333, SPUWaterAvailability@Seattle.Gov

Other Resources

- General questions about the permit process: Contact the SDCI Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [SDCI](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

Requirements

SDCI Drainage Requirements

The following requirements are based on the current stormwater and side sewer codes.

****The new 2016 Stormwater Code becomes effective on January 1, 2016. Projects with an accepted application (successful SDCI permit intake) date after December 31, 2015 will be reviewed under the new code. The drainage requirements indicated below are based on the 2016 Stormwater Code. If your project will be submitted prior to January 1, 2016, please contact the SDCI Drainage Reviewer to determine drainage requirements.****

Existing Public Drainage Infrastructure

Combined sewer main location: **15th Ave W**

Combined sewer main size: **8-inch Diameter**

Drainage

Infiltration Investigation Required: **No**

This project is in an area that does not require Infiltration Investigation

Project Type and Drainage Basin

The drainage point of discharge (SMC 22.805.020) is located at: **Combined sewer**

Project Type: **Parcel-based**

Drainage Basin: **Public combined sewer**

Drainage Control Compliance

Drainage Review Required: **Yes**

Drainage Control Review is required for this project per SMC 22.807.020. Submit a completed **Standard Construction Stormwater Control and Post Construction Soil Management (CSC/SOIL) Plan** and a completed **Standard Drainage and Wastewater Control (DWC) Plan** including the **Site and Drainage Control Summary** from [On-site Stormwater Management Calculator](#).

Note: For projects with 5,000 square feet or more of new plus replaced hard surface, a comprehensive drainage control plan, construction stormwater control plan, soil amendment plan, and drainage report shall be prepared by a licensed engineer.

Soil Amendment Required: **Yes**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.030.A, 22.805.040.A, or 22.805.050.A. Complete the **Post Construction Soil Management Plan** on the [Standard CSC/SOIL Plan](#).

On-site Stormwater Management Required: **Yes**

Parcel-based projects with 7,000 square feet or more of land disturbing activity, 1,500 square feet or more of new plus replaced hard surface or, if on a lot or parcel created or reduced in size on or after January 1, 2016,

750 square feet or more of new plus replaced hard surface, must implement **On-site Stormwater Management** (infiltration, dispersion, bioretention, green roofs, permeable pavement, rainwater harvesting, etc.) to manage runoff from all hard surfaces on-site per SMC 22.805.050.B. and Director's Rule 21-2015.

Flow control standards must be first met by utilizing **On-site Stormwater Management** to the maximum extent feasible. Additional flow control measures shall be installed if the flow control standard cannot be met solely using On-site Stormwater Management BMP's.

Submit an [On-site Stormwater Management Calculator](#) and show the On-site Stormwater Management BMP's and surface designation on the [Standard Drainage and Wastewater Control Plan](#).

Flow Control Required: **Peak Flow Control Standard**

This project site discharges to a **Public Combined Sewer** (SMC 805.050.C.5). Based upon the information provided on the Preliminary Application Form pertaining to land disturbing activity and existing and proposed hard surfacing, this project shall provide flow control meeting the **Peak Flow Control Standard** per SMC 22.805.080.B.4. The post-development peak flow with a 4% annual probability (25-year recurrence flow) shall not exceed 0.4 cubic feet per second per acre. Additionally, the peak flow with a 50% annual probability (2-year recurrence flow) shall not exceed 0.15 cubic feet per second per acre.

Projects with less than 10,000 sf new plus replaced hard surface can use the [Pre-Sized Flow Control Calculator](#) in lieu of continuous modeling.

Water Quality

No requirements

Wastewater

The wastewater point of discharge (SMC 21.16.070.B) is located at Combined Sewer - 15th Ave W.

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a [King County Capacity Charge](#).

Permanent and Temporary Dewatering

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following: Combined system.

Side Sewer

The existing side sewer for a new or converted building or dwelling unit may be reused pursuant to SMC 21.16.240.

If there is an increase of dwelling units or buildings the [Side Sewer Evaluation and Certification Form](#) must be completed by a licensed engineer.

See other requirements below

Other Requirements

- A maximum of 8 units may connect to the existing side sewer. There appears to be 22 units proposed and therefore would require the reuse of the existing side sewer plus two new 6" connections to the main.

SDCI Land Use Code Requirements

Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at SDCI permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to SDCI permit application intake.

15TH AVE W

Drainage may be required to be installed in the portion of right-of-way abutting this lot. Please contact SDOT for more information.

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.
<http://www.seattle.gov/transportation/treeplanting.htm>.

Other requirements: Demo permit is required to remove the billboard.

Alley Requirements

ALLEY E OF SITE

Pave the width of the alley abutting the lot and the portion of alley between the lot and the connecting street. The Seattle Right of Way Improvements Manual (http://www.seattle.gov/transportation/stuse_docs.htm) contains design details.

A 2 feet foot dedication is required. Refer to SDOT CAM 2203. Please see http://www.seattle.gov/transportation/stuse_docs.htm.

Land Use

Based on the project scope and/or location of environmentally critical areas on the development site, SEPA may be required. See CAM 208 for more details.

Design Review is required; see CAM 238 for more details. Departures from development standards should be identified as early as possible in the application process.

Preliminary screening of your project has been completed and it appears that your proposal is located in an environmentally critical area (ECA) which may require an ECA review and SEPA. For additional information about ECAs and SEPA, visit the DPD website (<http://www.seattle.gov/dpd/Codes/>).

An arborist report may be required. See CAM 242 for more detail.

Alley access may be required

Other Requirements

A presubmittal conference is required before to submitting an application. Details for preparing and submitting a presubmittal request form can be found at our Web site ([http://www.seattle.gov/dpd/Publications/Forms/Building Permits/default.asp](http://www.seattle.gov/dpd/Publications/Forms/Building_Permits/default.asp)).

Since your development proposal includes alteration or demo of a 50+ year old structure, you are required to submit a "referral" to the Historic Preservation Program at Department of Neighborhoods (DON). DON staff will review the eligibility of the structure as a landmark. This determination must be made before you can schedule an intake appointment for your project.

Please see [Client Assistance Memo 3000](#) titled "DPD and DON Referral Process for Determining Landmark Eligibility" (pages 3-4). Your referral application should include a response to the "Appendix A of the Interdepartmental Agreement" on page 6 of the CAM. The referral information should be sent to "Karen Gordon, City Historic Preservation Officer, Department of Neighborhoods, PO Box 94649, Seattle, WA 98124".

Once the DON staff review the information contained in your referral, one of the following three determinations will be made:

- 1) The building appears to be ineligible as a landmark and no further Department of Neighborhoods review is required. You may schedule your intake appointment.
- 2) The subject building appears to be eligible and a Landmark Nomination application must be submitted to the DON Historic Preservation Program. This application and determination must occur before DPD permit intake since the outcome of this landmark nomination decision may affect the design or feasibility of your project.
- 3) The subject building/site is determined to be a designated City Landmark. A Certificate of Approval from the Landmarks Preservation Board is required for changes proposed to the designated features of the Landmark. You will need provide a copy of your application for a Landmark Certificate of Approval prior to permit intake. No DPD permit will not be issued until the Certificate of Approval has been issued.

Pre-Application Site Visit (PASV) Requirements

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all**

required documents at the intake appointment. If you have questions about this report or the PASV process, please contact the SDCI Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by SDCI within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

ECA Mapping Unit and Type

This project site appears to include the following ECAs and/or buffers:

Steep slope

Potential slide

Earth Disturbance

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

Existing ROW Conditions

15TH AVE W

Street conditions:

Asphalt paving

Curb conditions:

Concrete

Approximate curb height: 2-3" VARIABLE inches

A storm inlet does not appear to be located <350 ft from the site and prior to crossing a public right of way.

ALLEY E OF SITE

Unimproved

Comments: Has very large and deep potholes

Potential Impacts to Seattle Parks Property

No parks property in vicinity

Tree Protection

Trees greater than 6 inches in diameter as measured 4.5 ft above ground are present on the site but not shown on the site plan. Show the dripline of

1) **all** trees on the site,

2) adjacent trees that encroach on the site that are greater than 6 inches in diameter as measured 4.5 ft above ground, and

3) **all** trees located in the adjacent ROW.

Include common and scientific names for all trees shown. For more information, see [Director's Rule 16-2008](#) and [Tip 242](#).

Construction Stormwater Control

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 21-2015, Volume 2](#)).

Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):

Place filter fabric, straw bales, straw wattles, or other approved equal to control construction stormwater runoff. Required along the following property lines:

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](http://web1.seattle.gov/DPD/InspectionRequest/default.aspx) at <http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

Inspectors Notes

Not mapped as a steep slope but fits the criteria for steep slope. A rise of 10' high over a distance of 25 feet or less.

Standard Submittal Requirements for Projects in an ECA

Submit a geotechnical report with the permit intake submittal package. Geotechnical report must be signed and stamped by a geotechnical engineer licensed in the State of Washington per [SMC 22.170.070](#), [SMC 25.09](#), and [Directors Rule \(DR\) 18-2011](#).

Provide a topographic survey with 2-foot contours on and within 25-feet of the property, stamped by a licensed land surveyor (see [25.09.330A](#))

Delineate the clearing limits on the site plan

Provide a vegetation restoration plan per SMC [25.09.320](#), [Tip 331](#) and [Tip 331A](#). **Prior to any vegetation removal in the critical area, review, approval, and a preconstruction meeting is required**

Delineate the steep slope critical area on a site plan based on the survey (per SMC 25.09.020 A3b(5)).

Provide area calculations for the steep slope delineation.

Show the steep slope buffer. Generally, the buffer is 15-feet from the top and/or toe of the slope

Construction activity area appears to be within the steep slope critical area and/or its associated buffer. A steep slope variance may be required (see SMC 25.09.180E.1)

An ECA pre-submittal conference is strongly recommended. Call the Applicant Services Center (206-684-8850) to schedule an appointment

Seattle City Light Requirements

Street/Alley Requirements

ALLEY E OF SITE

Clearance from Structures: 10-ft horizontal clearance is required between power lines and any part of the permanent structure. Vertically, 12.5 to 13.5 feet is required depending on access to pedestrians. Additional clearance (14 feet total) is highly recommended to account for working clearance and future building maintenance. Review DPD TIP 122, Electric Utility Clearance Requirements, and SCL Construction Guideline D2-3 (<http://www.seattle.gov/Light/engstd/Docs/ConStd/d23.pdf>). Transmission lines require greater clearance. Changes to SCL's system to meet clearances are done at the project's expense. There is an overhead high voltage line along the alley.

Working Clearance: State law requires construction workers, their tools, machinery, equipment, and materials to maintain a 10-foot clearance from power lines. Review WAC 296-24-960 and OSHA 1910.333(c)(3)(i). Transmission lines require greater clearance. To work near power lines, notify SCL well in advance to de-energize and ground the lines, or relocate the lines temporarily. This City Light work is done at the project's expense. City Light may not be able to grant customer requests to temporarily relocate or de-energize the distribution system. There is an overhead high voltage line along the alley.

An SCL engineer will require scaled building elevation drawings to determine clearances. Please submit an extra set of plans at DPD intake.

Other requirements: If three-phase power is needed, an extension of City Light's distribution system is required to provide power to the project site.

Based on our assessment of the size of your project, you may need transformers on your private property for power service to your building. This can be done with vaults inside the building, below-grade vaults, or above-grade pads exterior to the building. Include these facilities for your project power needs in your building plans. SCL has access, clearance, size and location requirements for vaults. Some transformers require long lead times to obtain. Contact SCL well in advance to provide electrical service size and voltage details.

Other requirements: Relocating a City Light pole may be required if proposed parking locations conflict with the existing pole location. Relocation is at the project's expense. Contact your Electrical Service Representative for further discussion.

Easements

SCL power easement is required. Property survey may be required at project's expense.

SCL blanket power easement over the entire parent parcel may be required. Property survey may be required at project's expense. If this is a unit lot subdivision, a blanket easement is needed.

Other requirements: The parent parcel is considered one site. The electrical service to the new buildings will need to be consolidated from one service strike from SCL's distribution system. Per SCL Requirements for Electric Service Connection, <http://www.seattle.gov/light/contractors/resc/>, Chapter 5, page 28: "Single Service Rule", Seattle City Light will provide only one service to a site or building. Additional services will be supplied only at SCL's option and will be agreed to in writing. If subdivided to create separate parcels, each parcel must have a separate service. An easement sufficient in width for an overhead or underground service is required. Clearance from permanent structures and other utilities is also required. Please contact your Electrical Service Representative well in advance of construction for clarification and electrical service advice.

Conservation

Built Smart Programs - SCL offers developers of 5+ unit multifamily buildings incentives for installation of energy efficiency measures. From insulation and windows to lighting and appliances, take advantage of new technologies and construct a more efficient building with our help. For more information: contact Beth Rocha at (206)684-5945 or beth.rocha@seattle.gov.

Notes to Applicant

For new service, please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. An Application for Electrical Service must be submitted to Seattle City Light. The Electrical Service Representative should also be contacted to coordinate electrical disconnections prior to demolition and temporary power for construction. Your Electrical Service Representative is: Carol Kenefick, 206-615-0611, carol.kenefick@seattle.gov. Be advised that it is the applicant's responsibility to seek guidance from City Light. Failure to contact City Light early in the permit process could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SDOT Requirements

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: http://www.seattle.gov/transportation/stuse_docs.htm. Whenever possible, specific reference notation for these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

SDOT Permitting Information

Initial Review Deposit: \$2,500

SDOT Plan Requirements: Engineered plan

SDOT Permit Requirements: Group 3: Street Use Major (Type 45). A 60% complete street improvement plan (SIP) must be approved by SDOT prior to your DPD construction intake appointment. SIP Design Guidance is required for 60% complete SIP approval; apply early. Please visit SDOT's Street Use website at: http://www.seattle.gov/transportation/stuse_sip.htm to obtain SDOT Client Assistance Memos (CAMs) and application materials to assist in developing your street improvement plan (SIP).

All private encroachments in the public right-of-way (ROW) require a 30-day permit that is renewed annually.

Street Improvement Requirements

15TH AVE W

Tree planting. See Seattle Right of Way Improvements Manual (ROWIM) and City of Seattle Standard Plans 030, 100 and 424. Contact SDOT Urban Forestry for residential projects at (206) 684-TREE; for all others at (206) 684-5693 for approval of species and placement.

All improvements on private property must accommodate the right of way elevation at the property line using the standard cross-section in the ROWIM. Right of way grading may be required to provide vehicular and pedestrian access that meets the standard cross-section.

New/replacement sidewalk: See Seattle Right of Way Improvements Manual (ROWIM) as well as the City of Seattle Standard Plan 420, 421 and 422. Repair & restoration of existing as needed.

Alley Requirements

ALLEY E OF SITE

Alley Grading: Standard alley cross section at established grade for portion of alley being improved. See Seattle Right of Way Improvements Manual (ROWIM) chapter 4. Apply for SDOT SIP Design Guidance. See SDOT CAM 2211.

Alley Drainage: Required for portion of alley being improved. A drainage review is required for any project which involves more than 750 sq ft of land disturbing activity in the public right-of-way. See Seattle Right of Way Improvements Manual (ROWIM) section 4.17.

Access via unopened/unimproved/unpaved alley. Grading, drainage and paving may be required. See Seattle Right of Way Improvements Manual (ROWIM) for improvement requirements.

Discretionary ROW Improvements

Utilities such as poles, utility vaults, and fire hydrants may need to be relocated to accommodate your required street improvements. See Right of Way Improvement Manual (ROWIM) section 4.20 for clearance requirements.

SPU Requirements

Flow Control Compliance

Soil Amendment. Retain and protect undisturbed soil in areas not being developed, and prior to completion of the project, amend all new, replaced, and disturbed topsoil (including construction lay-down areas) with organic matter to the extent required by and in compliance with the rules promulgated by the Director.

All roadway projects with 2,000 square feet or more of new plus replaced hard surface or 7,000 square feet or more of land disturbing activity shall meet the Minimum Requirements for On-site Stormwater Management contained in Section 22.805.070, to the extent allowed by law, except as provided in subsection 22.805.060.E.

In addition to applicable minimum requirements for flow control in subsection 22.805.060.C.1 through subsection 22.805.060.C.5, roadway projects discharging into a capacity-constrained system or its basin shall also comply with subsection 22.805.080.B.4 (Peak Control Standard) if the total new plus replaced hard surface is 10,000 square feet or more.

Water Availability

Your water availability assessment has been approved.

Water Availability Certificate reference number: 20160059

Water Availability Certificate status: Approved with No Changes

Prepared by: Michael Barrett

Existing Water System Information

Proximity of nearest fire hydrant is: 148 feet S of property. Meets standards.

Water Main:

Size: 20 inches	Material: Cast Iron	Class: C
- Standard		
- Abutting		

Water Main is available to serve in: 15th Avenue W

Distance of main to E margin of street is 20 feet.

Public ROW width is 113 feet.

Water Service(s):

Size: 3/4"	Material: Copper
Size: 3/4"	Material: Copper

Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to SDCI Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your SDCI intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes

before our SDCI intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, Michale.Crooks@seattle.gov, or visit the [Licensing and Tax Administration Division website](#).